



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH WP 12-56, **Version:** 2

Appeal of Saint Paul Ramsey County Department of Public Health to an Egress Window Non-Compliance Determination at 1370 SHELDON STREET.

[Enter the Reason for the Appeal]

May 29, 2012

No hearing necessary.

Yes, 3 inches egress opening height.

WHEREAS, in the matter of the Appeal of Saint Paul Ramsey County Department of Public Health to an Egress Window Non-Compliance Determination at 1370 SHELDON STREET ;the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 3-inch variance on the openable height of one double hung replacement egress bedroom window measuring 21-1/4 inches high by 28 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.