



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH FOW 12-148, **Version:** 2

---

Appeal of Karry Moua to a Fire Certificate of Occupancy Correction Notice at 986 BURR STREET.

One window only - H 18.5" X W 25"

April 6, 2012

Mike Cassidy

No hearing necessary.

Yes, 6 inches egress opening height.

WHEREAS, in the matter of the Appeal of Karry Moua to a Fire Certificate of Occupancy Correction Notice at 986 BURR STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 6-inch variance on the openable height of the egress window in the third floor bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.