



## Legislation Text

---

**File #:** RLH FOW 11-62, **Version:** 2

---

Appeal of Scott McCoy to a Fire Certificate of Occupancy Correction Notice at 1071 FOREST STREET.

Only Egress Windows

May 18, 2011

Yes, for units 101, 102 and 103, 8 inches in height of egress opening.

Yes, for units 202, 203 and 204, 5 inches in height of egress opening.

No, for unit 201 where egress opening height was measured at 11.5 inches.

Only on Unit 201.

### **AMENDED 7/6/2011**

WHEREAS, in the matter of the appeal of Scott McCoy to a Fire Certificate of Occupancy Correction Notice at 1071 FOREST STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer's recommendation is to grant variances of 8 inches in height of egress opening for units 101, 102 and 103; and grant variance of 5 inches in height of egress opening height for units 201, 202, 203 and 204; ~~and the balance of the recommendations for this appeal are forthcoming;~~  
Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.