



Legislation Details (With Text)

File #: RLH WP 11- 112 **Version:** 2

Type: Resolution LH Window Permit **Status:** Passed
In control: City Council
Final action: 12/7/2011

Title: Appeal of Midwest Roofing, on behalf of Marianna Skarda, to an Egress Window Non-Compliance Determination at 1255 EDMUND AVENUE.

Sponsors: Russ Stark

Indexes: Ward - 4, Windows

Code sections:

Attachments: 1. 1255 Edmund.appeal.11-02-11.pdf, 2. 1255 Edmund Ave.Midwest Exteriors Ltr 11-14-11.pdf

Date	Ver.	Action By	Action	Result
12/13/2011	2	Mayor's Office	Signed	
12/7/2011	2	City Council	Adopted	Pass
11/15/2011	1	Legislative Hearings	Referred	

Appeal of Midwest Roofing, on behalf of Marianna Skarda, to an Egress Window Non-Compliance Determination at 1255 EDMUND AVENUE.

Insert window/egress size

October 24, 2011

Kenny at Midwest?

No hearing necessary.

Yes, 4 inches in egress opening hieght.

WHEREAS, in the matter of the Appeal of Midwest Roofing, on behalf of Marianna Skarda, to an Egress Window Non-Compliance Determination at 1255 EDMUND AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the openable height of two insert/double hung replacement egress bedroom windows measuring 20.06 inches high by 25.34 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.