



Legislation Details (With Text)

File #: RLH WP 11- 105 **Version:** 2

Type: Resolution LH Window Permit **Status:** Passed
In control: City Council
Final action: 12/7/2011

Title: Appeal of Vicki Osterkamp to an Egress Window Non-Compliance Determination at 1402 FURNESS PARKWAY.

Sponsors: Dan Bostrom

Indexes: Ward - 6, Windows

Code sections:

Attachments: 1. 1402 Furness.appeal.10-28-11.pdf, 2. 1402 Furness Pkwy.Osterkamp Ltr 11-14-11.pdf, 3. 1402 Furness Pkwy.Osterkamp Ltr 11-15-11.pdf

Date	Ver.	Action By	Action	Result
12/13/2011	2	Mayor's Office	Signed	
12/7/2011	2	City Council	Adopted	Pass
11/15/2011	1	Legislative Hearings	Referred	

Appeal of Vicki Osterkamp to an Egress Window Non-Compliance Determination at 1402 FURNESS PARKWAY.

Bedroom window - Sorry my misunderstanding. I thought because Dave Nelson mailed me the letter--Egress Window Non-Compliance Determination--that I did have to send in this appeal. As you can see, on one form is said I need 5 sq ft, another form is said 5.7 sq ft. The form from Dave on my window is 8.3 sq ft... James the inspector came out today at 11:00 a.m. Explained that I need to do this to be oked I sure hope I did all these right now. If not I guess I start at square one again. Please let me know what else I have to do. Sorry. (paraphrased)

October 5, 2011

David Nelson

No hearing necessary. This looks as if it could have been an administration variance.

Yes, 2 inches in egress opening height.

WHEREAS, in the matter of the Appeal of Vicki Osterkamp to an Egress Window Non-Compliance Determination at 1402 FURNESS PARKWAY; the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of one double hung replacement egress bedroom window measuring 22 inches high by 26 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.

