



Legislation Details (With Text)

File #: RLH FCO 11- 487 **Version:** 2
Type: Resolution LH Fire C of O OR Correction Order **Status:** Passed
In control: City Council
Final action: 12/7/2011
Title: Appeal of James Becker to a Fire Certificate of Occupancy Correction Notice at 701/703 SHERWOOD AVENUE.
Sponsors: Dan Bostrom
Indexes: Fire C of O Letter, Ward - 6
Code sections:
Attachments: 1. 701and 703 Sherwood.appeal.10-24-11.pdf, 2. 701-703 Sherwood Ave.Becker Ltr 11-14-11.pdf

Date	Ver.	Action By	Action	Result
12/13/2011	2	Mayor's Office	Signed	
12/7/2011	2	City Council	Adopted	Pass
11/15/2011	1	Legislative Hearings	Referred	

Appeal of James Becker to a Fire Certificate of Occupancy Correction Notice at 701/703 SHERWOOD AVENUE.

#2. 1st floor bedroom window H 22" W 25"

#3. 2nd floor bedroom window H 21" W 25"

Both of these windows have an opening greater than code and allow egress. Replacing them will cause undue hardship and security risks.

Dryer exhaust vent had been updated with solid metal ductwork. If permit is demanded, dryer will be removed.

October 11, 2011

Mike Cassidy

No hearing necessary.

Yes: first floor southwest bedroom - 2 inch variance in egress opening height; second floor bedroom 3 inch variance in egress opening height.

WHEREAS, in the matter of the Appeal of James Becker to a Fire Certificate of Occupancy Correction Notice at 701/703 SHERWOOD AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of the egress window in the first floor southeast bedroom and a 3-inch variance on the openable height of the egress window in the 2nd floor bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's

recommendation in this matter.