



Legislation Details (With Text)

File #: RLH WP 11- 124 **Version:** 2

Type: Resolution LH Window Permit **Status:** Passed

In control: City Council

Final action: 12/21/2011

Title: Appeal of Scherer Window and Door (Chris Judd), on behalf of Ben Osmond, to an Egress Window Non-Compliance Determination at 872 KENNETH STREET.

Sponsors: Pat Harris

Indexes: Ward - 3, Windows

Code sections:

Attachments: 1. 872 Kenneth.appeal.11-30-11.pdf, 2. 872 Kenneth St.Judd Ltr 12-5-11.pdf

Date	Ver.	Action By	Action	Result
12/29/2011	2	Mayor's Office	Signed	
12/21/2011	2	City Council	Adopted	Pass
12/6/2011	1	Legislative Hearings	Referred	

Appeal of Scherer Window and Door (Chris Judd), on behalf of Ben Osmond, to an Egress Window Non-Compliance Determination at 872 KENNETH STREET.

See attachment

No date

None indicated

No hearing necessary.

Yes, 2 inches egress opening height.

WHEREAS, in the matter of the Appeal of Scherer Window and Door (Chris Judd), on behalf of Ben Osmond, to an Egress Window Non-Compliance Determination at 872 KENNETH STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of two double hung replacement egress bedroom windows measuring 22.375 inches high by 42.1 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.