

City of Saint Paul

City Hall and Court House 15 West Kellogg Boulevard Phone: 651-266-8560

Legislation Details (With Text)

File #: RLH FOW 11- Version: 2

229

Type: Resolution LH Fire Ordered

Windows

Status: Passed

In control: City Council

Final action: 12/21/2011

Title: Appeal of Lawrence F. Yarusso and Vicki Imdicke, Power of Attorney, to a Fire Certificate of

Occupancy Correction Notice at 1260 EARL STREET.

Sponsors: Dan Bostrom

Indexes: Fire C of O Letter, Ward - 6, Windows

Code sections:

Attachments: 1. 1260 Earl.appeal.10-31-11.pdf, 2. 1260 Earl St.Imdieke Ltr 11-21-11.pdf

Date	Ver.	Action By	Action	Result
12/29/2011	2	Mayor's Office	Signed	
12/21/2011	2	City Council	Adopted	Pass
11/22/2011	1	Legislative Hearings	Referred	

Appeal of Lawrence F. Yarusso and Vicki Imdicke, Power of Attorney, to a Fire Certificate of Occupancy Correction Notice at 1260 EARL STREET.

See attached copy-number 6.

October 24, 2011

Mike Cassidy

No hearing necessary.

Yes, for west bedroom 3 inches in egress opening height.

WHEREAS, in the matter of the Appeal of Lawrence F. Yarusso and Vicki Imdicke, Power of Attorney, to a Fire Certificate of Occupancy Correction Notice at 1260 EARL STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2.5-inch variance on the openable height of the egress window in the west bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.