



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Details (With Text)

File #: RLH FOW 11- **Version:** 2
240

Type: Resolution LH Fire Ordered Windows **Status:** Passed

In control: City Council

Final action: 12/21/2011

Title: Appeal of Tony Swanson, Public Housing Agency of St. Paul, to a Fire Certificate of Occupancy Correction Notice at 1500 DANFORTH STREET.

Sponsors: Lee Helgen

Indexes: Fire C of O Letter, Ward - 5, Windows

Code sections:

Attachments: 1. 1500 Danforth.appeal.11-9-11.pdf, 2. 1500 Danforth St.PHA Ltr 11-21-11.pdf

Date	Ver.	Action By	Action	Result
12/29/2011	2	Mayor's Office	Signed	
12/21/2011	2	City Council	Adopted	Pass
11/22/2011	1	Legislative Hearings	Referred	

Appeal of Tony Swanson, Public Housing Agency of St. Paul, to a Fire Certificate of Occupancy Correction Notice at 1500 DANFORTH STREET.

#3 Interior - MSFC 1026.1. Request variance on openable width.

October 27, 2011

Rick Gavin

No hearing necessary.

Yes, 3 inches in egress opening width.

WHEREAS, in the matter of the Appeal of Tony Swanson, Public Housing Agency, to a Fire Certificate of Occupancy Correction Notice at 1500 DANFORTH STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 3-inch variance on the openable width of the egress bedroom windows; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.