



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Details (With Text)

File #: RLH WP 11- 115 **Version:** 2
Type: Resolution LH Window Permit **Status:** Passed
In control: City Council
Final action: 12/21/2011
Title: Appeal of Installation Masters Inc., on behalf of Tony and Katy Harms, to an Egress Window Non-Compliance Determination at 1013 GROTTA STREET NORTH.
Sponsors: Lee Helgen
Indexes: Ward - 5, Windows
Code sections:
Attachments: 1. 1013 Grotto.appeal.11-11-11.pdf, 2. 1013 Grotto St N.Installation Masters Ltr 11-21-11.pdf

Date	Ver.	Action By	Action	Result
12/29/2011	2	Mayor's Office	Signed	
12/21/2011	2	City Council	Adopted	Pass
11/22/2011	1	Legislative Hearings	Referred	

Appeal of Installation Masters Inc., on behalf of Tony and Katy Harms, to an Egress Window Non-Compliance Determination at 1013 GROTTA STREET NORTH.

None listed

October 31, 2011

Virgil Thomas

No hearing necessary.

Yes, 7 inches in egress opening height.

WHEREAS, in the matter of the Appeal of Installation Masters Inc., on behalf of Tony and Katy Harms, to an Egress Window Non-Compliance Determination at 1013 GROTTA STREET NORTH, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 7-inch variance on the openable height of three replacement egress bedroom windows measuring 17 inches high by 36 and 28 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.