



## Legislation Details (With Text)

**File #:** RLH WP 11- 114 **Version:** 2

**Type:** Resolution LH Window Permit **Status:** Passed  
**In control:** City Council  
**Final action:** 12/21/2011

**Title:** Appeal of Budget Exterior, on behalf of Ronald Burth and Shannon Burth McDonald, to two Egress Window Non-Compliance Determinations at 1077 ENGLEWOOD AVENUE.

**Sponsors:** Melvin Carter III

**Indexes:** Ward - 1, Windows

**Code sections:**

**Attachments:** 1. 1077 Englewood.appeal.11-9-11.pdf, 2. 1077 Englewood Ave.Budget Exteriors Ltr 11-29-11.pdf

Date	Ver.	Action By	Action	Result
12/29/2011	2	Mayor's Office	Signed	
12/21/2011	2	City Council	Adopted	Pass
11/22/2011	1	Legislative Hearings	Referred	

Appeal of Budget Exterior, on behalf of Ronald Burth and Shannon Burth McDonald, to two Egress Window Non-Compliance Determinations at 1077 ENGLEWOOD AVENUE.

Windows

November 3, 2011 for both

J. Hoffman

Yes, a 5 inch variances in egress opeing height for 4 double hung windows with egress opening dimensions of 5 inches in egress opening dimensions of 21"W and 19"H.

Hearing required for 2 double hung windows with egress opening dimensions of 15"H and 17"W.

WHEREAS, in the matter of the Appeal of Budget Exterior, on behalf of Ronald Burth and Shannon Burth McDonald, to two Egress Window Non-Compliance Determinations at 1077 ENGLEWOOD AVENUE; the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of four double hung replacement egress bedroom windows measuring 19-1/6 inches high by 21-3/4 inches wide, and deny the appeal on two double hung replacement egress bedroom windows measuring 15-1/16 inches high by 17-3/4 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.