



Legislation Details (With Text)

File #: RLH WP 11- 117 **Version:** 2

Type: Resolution LH Window Permit **Status:** Passed
In control: City Council
Final action: 12/21/2011

Title: Appeal of Daniel Schmidt, Department of Public Health, on behalf of Lue Williams, to an Egress Window Non-Compliance Determination 844 FULLER AVENUE.

Sponsors: Melvin Carter III

Indexes: Ward - 1, Windows

Code sections:

Attachments: 1. 844 Fuller.appeal.11-16-11.pdf, 2. 844 Fuller Ave.Public Health Ltr 12-5-11.pdf

Date	Ver.	Action By	Action	Result
12/29/2011	2	Mayor's Office	Signed	
12/21/2011	2	City Council	Adopted	Pass
12/6/2011	2	Legislative Hearings	Referred	

Appeal of Daniel Schmidt, Department of Public Health, on behalf of Lue Williams, to an Egress Window Non-Compliance Determination 844 FULLER AVENUE.

[Enter the Reason for the Appeal]

November 16, 2011

Public Health.

No hearing necessary.

Yes, 2 inches in egress opening height.

WHEREAS, in the matter of the Appeal of Daniel Schmidt, Department of Public Health, on behalf of Lue Williams, to an Egress Window Non-Compliance Determination 844 FULLER AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of three double hung replacement egress bedroom windows measuring 22.6 inches high by 22 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.