



Legislation Details (With Text)

File #: RLH FOW 11- **Version:** 2
258

Type: Resolution LH Fire Ordered Windows **Status:** Passed

In control: City Council

Final action: 1/4/2012

Title: Appeal of Kawkheelar Hsa Moo to a Fire Certificate of Occupancy Correction Notice at 354 WHEELLOCK PARKWAY EAST.

Sponsors: Amy Brendmoen

Indexes: Fire C of O Letter, Ward - 5, Windows

Code sections:

Attachments: 1. 354 Wheelock.appeal.11-30-11.pdf, 2. 354 Wheelock Pkwy E.Moo Ltr 12-12-11.pdf

Date	Ver.	Action By	Action	Result
1/12/2012	2	Mayor's Office	Signed	
1/4/2012	2	City Council	Adopted	Pass
12/13/2011	1	Legislative Hearings	Referred	

Appeal of Kawkheelar Hsa Moo to a Fire Certificate of Occupancy Correction Notice at 354 WHEELLOCK PARKWAY EAST.

Egress windows

November 21, 2011

James Perucca

No hearing necessary.

Yes, 4 inches egress opening height.

WHEREAS, in the matter of the Appeal of Kawkheelar Hsa Moo to a Fire Certificate of Occupancy Correction Notice at 354 WHEELLOCK PARKWAY EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the openable height of the egress windows in the northeast, southeast, and over garage northside bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.