



Legislation Details (With Text)

File #: RLH FOW 11- **Version:** 2
261

Type: Resolution LH Fire Ordered Windows **Status:** Passed

In control: City Council

Final action: 1/18/2012

Title: Appeal of James Rossman to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 54 CHATSWORTH STREET SOUTH.

Sponsors: Dave Thune

Indexes: Fire C of O Letter, Ward - 2, Windows

Code sections:

Attachments: 1. 54 Chatsworth.appeal.12-5-11.pdf, 2. 54 Chatsworth St S.Rossman Ltr 12-20-11.pdf

Date	Ver.	Action By	Action	Result
4/18/2012	2	Mayor's Office	Signed	
1/24/2012	2	Mayor's Office	Signed	
1/18/2012	2	City Council	Adopted	Pass
12/20/2011	1	Legislative Hearings	Referred	

Appeal of James Rossman to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 54 CHATSWORTH STREET SOUTH.

Existing windows, "grandfathered".

November 29, 2011

Rick Gavin

No hearing necessary.

Yes: unit 1 - 1 inch egress opening height; Unit 3 - 3 inches egress opening height; Unit 4 - 3 inches egress opening height.

WHEREAS, in the matter of the Appeal of James Rossman to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 54 CHATSWORTH STREET SOUTH, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant bedroom window variances in Units 1, 3 and 4; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.