



## Legislation Details (With Text)

**File #:** RLH FOW 11- **Version:** 2  
274

**Type:** Resolution LH Fire Ordered Windows **Status:** Passed

**In control:** City Council

**Final action:** 1/18/2012

**Title:** Appeal of Bie Drake to a Correction Notice-Daycare Inspection at 1309 MAYNARD DRIVE WEST.

**Sponsors:** Chris Tolbert

**Indexes:** Fire C of O Letter, Ward - 3, Windows

**Code sections:**

**Attachments:** 1. 1309 Maynard W.appeal.12-12-11.pdf, 2. 1309 Maynard Dr W.Drake Ltr 12-20-11.pdf

Date	Ver.	Action By	Action	Result
4/18/2012	2	Mayor's Office	Signed	
1/24/2012	2	Mayor's Office	Signed	
1/18/2012	2	City Council	Adopted	Pass
12/20/2011	1	Legislative Hearings	Referred	

Appeal of Bie Drake to a Correction Notice-Daycare Inspection at 1309 MAYNARD DRIVE WEST.

The minimum size of glazed area with a minimum of 22 inches instead of 24 inches of openable height.

December 5, 2011

James Perruca

No hearing necessary.

Yes, 2 inches egress opening height.

WHEREAS, in the matter of Appeal of Bie Drake to a Correction Notice-Daycare Inspection at 1309 MAYNARD DRIVE WEST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of the egress windows in bedroom 1 east window and bedroom 2 south window; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.