



Legislation Details (With Text)

File #: RLH FOW **Version:** 2
12-12

Type: Resolution LH Fire Ordered **Status:** Passed
Windows

In control: City Council

Final action: 2/1/2012

Title: Appeal of Vatou Her to a Fire Certificate of Occupancy Correction Notice at 614 ROSE AVENUE.

Sponsors: Dan Bostrom

Indexes: Fire C of O Letter, Ward - 6, Windows

Code sections:

Attachments: 1. 614 Rose.appeal.12-22-11.pdf, 2. 614 Rose Ave E.Her Ltr 1-5-12.pdf

Date	Ver.	Action By	Action	Result
2/7/2012	2	Mayor's Office	Signed	
2/1/2012	2	City Council	Adopted	Pass
1/3/2012	1	Legislative Hearings	Referred	

Appeal of Vatou Her to a Fire Certificate of Occupancy Correction Notice at 614 ROSE AVENUE.

Two window size - 21 in. height x 26.5 in. wide, 19 in. height x 25.5 in. width

December 14, 2011

Mike Cassidy

No hearing necessary.

Her was called and told that the appeal has been granted on the windows. -rrn

Yes, 3 inches egress opening height - first floor and 5 inches egress opening height - second floor.

WHEREAS, in the matter of the Appeal of Vatou Her to a Fire Certificate of Occupancy Correction Notice at 614 ROSE AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 3-inch variance on the openable height of the egress window in the first floor bedroom and a 5-inch variance on the openable height of the egress windows in the 2nd floor northeast and northwest bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.