



Legislation Details (With Text)

File #: RLH FOW **Version:** 2
12-5

Type: Resolution LH Fire Ordered **Status:** Passed
Windows

In control: City Council

Final action: 2/1/2012

Title: Appeal of Tony Swanson, oh behalf of the Saint Paul Public Housing Agency, to a Fire Certificate of Occupancy Inspection Correction Notice at 489 IDAHO AVENUE EAST.

Sponsors: Amy Brendmoen

Indexes: Fire C of O Letter, Ward - 5, Windows

Code sections:

Attachments: 1. 489 Idaho.appeal.12-16-11.pdf, 2. 489 Idaho Ave E.PHA Ltr 1-5-12.pdf

Date	Ver.	Action By	Action	Result
2/7/2012	2	Mayor's Office	Signed	
2/1/2012	2	City Council	Adopted	Pass
1/3/2012	1	Legislative Hearings	Referred	

Appeal of Tony Swanson, oh behalf of the Saint Paul Public Housing Agency, to a Fire Certificate of Occupancy Inspection Correction Notice at 489 IDAHO AVENUE EAST.

#1 Main Floor Sleeping Rooms - Request variance on openable width.

December 6, 2011

Sean Westenhofer

No hearing necessary.

Voice mail message left for Swanson that appeal has been granted. -rrn

Yes, 5 inches egress opening height.

WHEREAS, in the matter of the Appeal of Tony Swanson, Saint Paul Public Housing Agency, to a Fire Certificate of Occupancy Inspection Correction Notice at 489 IDAHO AVENUE EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 1-inch and a 2-inch variance on the openable width of the egress windows in the main floor sleeping rooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.