



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Details (With Text)

**File #:** RLH FOW      **Version:** 2  
12-26

**Type:** Resolution LH Fire Ordered Windows      **Status:** Passed

**In control:** City Council

**Final action:** 2/1/2012

**Title:** Appeal of Kimberly Farr to a Fire Certificate of Occupancy Correction Notice at 910 SELBY AVENUE.

**Sponsors:** Melvin Carter III

**Indexes:** Fire C of O Letter, Ward - 1, Windows

**Code sections:**

**Attachments:** 1. 910 Selby.appeal.1-6-12.pdf, 2. 910 Selby Ave.Farr Ltr 1-18-12.pdf

Date	Ver.	Action By	Action	Result
2/7/2012	2	Mayor's Office	Signed	
2/1/2012	2	City Council	Adopted	Pass
1/17/2012	1	Legislative Hearings	Referred	

Appeal of Kimberly Farr to a Fire Certificate of Occupancy Correction Notice at 910 SELBY AVENUE.

A window in a bedroom

December 9, 2011

Rick Gavin

No hearing necessary.

Yes, 2 inches egress opening height.

WHEREAS, in the matter of the Appeal of Kimberly Farr to a Fire Certificate of Occupancy Correction Notice at 910 SELBY AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of the egress window in the northeast bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.