



## Legislation Details (With Text)

**File #:** RLH FOW      **Version:** 2  
12-49

**Type:** Resolution LH Fire Ordered      **Status:** Passed  
Windows

**In control:** City Council

**Final action:** 3/7/2012

**Title:** Appeal of Tony Swanson, on behalf of Public Housing Agency of St. Paul, to a Fire Certificate of Occupancy Correction Notice at 1876 IOWA AVENUE EAST.

**Sponsors:** Dan Bostrom

**Indexes:** Fire C of O Letter, Ward - 6, Windows

**Code sections:**

**Attachments:** 1. 1876 Iowa.appeal.1-23-12, 2. 1876 Iowa Ave E.Swanson Ltr.1-31-12.pdf

Date	Ver.	Action By	Action	Result
3/13/2012	2	Mayor's Office	Signed	
3/7/2012	2	City Council	Adopted	Pass
2/7/2012	1	Legislative Hearings	Referred	

Appeal of Tony Swanson, on behalf of Public Housing Agency of St. Paul, to a Fire Certificate of Occupancy Correction Notice at 1876 IOWA AVENUE EAST.

#1 - Request variance on openable height.

January 12, 2012

James Thomas

No hearing necessary.

Yes, 2 inches egress opening height.

WHEREAS, in the matter of the Appeal of Tony Swanson, on behalf of Public Housing Agency of St. Paul, to a Fire Certificate of Occupancy Correction Notice at 1876 IOWA AVENUE EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of the egress bedroom windows; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.