



## Legislation Details (With Text)

**File #:** RLH FOW      **Version:** 2  
12-53

**Type:** Resolution LH Fire Ordered Windows      **Status:** Passed

**In control:** City Council

**Final action:** 3/21/2012

**Title:** Appeal of Nancy Olson to a Fire Certificate of Occupancy Inspection Correction Notice at 1398 MECHANIC AVENUE.

**Sponsors:** Dan Bostrom

**Indexes:** Fire C of O Letter, Ward - 6, Windows

**Code sections:**

**Attachments:** 1. 1398 Mechanic.appeal.2-1-12.pdf, 2. 1389 Schletti St.Renewal by Andersen Ltr 1-26-12.pdf

Date	Ver.	Action By	Action	Result
3/27/2012	2	Mayor's Office	Signed	
3/21/2012	2	City Council	Adopted	Pass
2/14/2012	1	Legislative Hearings	Referred	

Appeal of Nancy Olson to a Fire Certificate of Occupancy Inspection Correction Notice at 1398 MECHANIC AVENUE.

Windows measure 20" High X 35" Wide

December 27, 2011

James Thomas

No hearing necessary.

Yes, 4 inches egress opening height.

WHEREAS, in the matter of the Appeal of Nancy Olson to a Fire Certificate of Occupancy Inspection Correction Notice at 1398 MECHANIC AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the openable height of the egress windows in all bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.