



## Legislation Details (With Text)

**File #:** RLH FOW      **Version:** 2  
12-54

**Type:** Resolution LH Fire Ordered Windows      **Status:** Passed

**In control:** City Council

**Final action:** 3/21/2012

**Title:** Appeal of Tony Swanson, Public Housing Agency of St. Paul, to a Fire Certificate of Occupancy Inspection Correction Notice at 1294 EDGERTON STREET.

**Sponsors:** Dan Bostrom

**Indexes:** Fire C of O Letter, Ward - 6, Windows

**Code sections:**

**Attachments:** 1. 1294 Edgerton.appeal.2-1-12.pdf, 2. 1294 Edgerton St.Swanson Ltr 2-13-12.pdf

Date	Ver.	Action By	Action	Result
3/27/2012	2	Mayor's Office	Signed	
3/21/2012	2	City Council	Adopted	Pass
2/14/2012	1	Legislative Hearings	Referred	

Appeal of Tony Swanson, Public Housing Agency of St. Paul, to a Fire Certificate of Occupancy Inspection Correction Notice at 1294 EDGERTON STREET.

#1 1st Floor South Bedroom  
#2 1st Floor West Bedroom  
#4 2nd Floor S and N Bedrooms  
Request variance on all openable heights.

January 25, 2012

Mike Cassidy

No hearing necessary.

Yes, 5.5 inches egress opening height and 4 inch egress opening height

WHEREAS, in the matter of the Appeal of Tony Swanson, Public Housing Agency of St. Paul, to a Fire Certificate of Occupancy Inspection Correction Notice at 1294 EDGERTON STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5.5-inch variance on the openable height of the egress window in the first floor south bedroom, and grant a 4-inch variance on the openable height of the egress windows in the first floor west and 2nd floor south and north bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.

