



Legislation Details (With Text)

File #: RLH WP 12- 22 **Version:** 2
Type: Resolution LH Window Permit **Status:** Passed
In control: City Council
Final action: 3/21/2012
Title: Appeal of The Window Store Home Improvements, on behalf of Judy Bollmann, to two Egress Window Non-Compliance Determinations at 910 CASE AVENUE.
Sponsors: Dan Bostrom
Indexes: Ward - 6, Windows
Code sections:
Attachments: 1. 910 Case.appeal.2-15-12.pdf, 2. 910 Case Ave.Window Store Ltr 2-24-12.pdf

| Date | Ver. | Action By | Action | Result |
|-----------|------|----------------------|----------|--------|
| 3/27/2012 | 2 | Mayor's Office | Signed | |
| 3/21/2012 | 2 | City Council | Adopted | Pass |
| 2/21/2012 | 1 | Legislative Hearings | Referred | |

Appeal of The Window Store Home Improvements, on behalf of Judy Bollmann, to two Egress Window Non-Compliance Determinations at 910 CASE AVENUE.

Needs DH windows for AC units.

February 15, 2012

"DD"

No hearing necessary.

Yes, 1.2 square feet total glazed area and 8 inches egress opening height.

WHEREAS, in the matter of the Appeal of The Window Store Home Improvements, on behalf of Judy Bollmann, to two Egress Window Non-Compliance Determinations at 910 CASE AVENUE; the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 1.2 (1.068) square ft. variance on the total glazed area of two double hung replacement windows measuring 24 inches high by 23.594 inches wide, grant a 1.5 (1.517) square ft. variance on the total glazed area, and an 8-inch variance on the openable height of one double hung replacement window measuring 16 inches high by 31.344 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.