

City of Saint Paul

City Hall and Court House 15 West Kellogg Boulevard Phone: 651-266-8560

Legislation Details (With Text)

File #: RLH FCO 12- Version: 2

68

Type: Resolution LH Fire C of O OR Status:

Correction Order

In control: City Council

Passed

Final action: 3/7/2012

Title: Appeal of Taib K. Ansera to a Fire Certificate of Occupancy Correction Notice at 1133 ARUNDEL

STREET.

Sponsors: Amy Brendmoen

Indexes: Fire C of O Letter, Ward - 5, Windows

Code sections:

Attachments: 1. 1133 Arundel.appeal.1-24-12, 2. 1133 Arundel.Fire C of O.1-10-08.pdf, 3. 1133 Arundel.Fire C of

O.2-12-08.pdf, 4. 1133 Arundel.Photos.12-30-11.pdf, 5. 1133 Arundel St.Ansera Ltr 2-14-12.pdf

Date	Ver.	Action By	Action	Result
3/13/2012	2	Mayor's Office	Signed	
3/7/2012	2	City Council	Adopted	Pass
2/7/2012	1	Legislative Hearings	Referred	

Appeal of Taib K. Ansera to a Fire Certificate of Occupancy Correction Notice at 1133 ARUNDEL STREET.

- 1. Height of ceiling
- 2. Size of windows and we have a patio sliding door in the basement bedroom as the escape window.
- 3. Want to know if we have to do it because we are going to redo the driveway in the spring and put a two car garage in the back yard.

December 30, 2011

Lisa Martin

Hearing necessary on basement and driveway portions of the appeal.

Yes, 7 and 1 inch in egress opening height respectively in the egress opening height.

WHEREAS, in the matter of the Appeal of Taib K. Ansera to a Fire Certificate of Occupancy Correction Notice at 1133 ARUNDEL STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 7-inch variance on the openable height of the egress windows in the main floor bedroom; grant a 1-inch variance on the openable height of the egress windows in the second floor bedroom; grant a 6-inch variance on the ceiling height in the basement; and deny the appeal on the driveway issue and grant an extension to September 1, 2012 for compliance.; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.

File #: RLH FCO 12-68, Version: 2