



Legislation Details (With Text)

File #: RLH WP 12-19 **Version:** 2
Type: Resolution LH Window Permit **Status:** Passed
In control: City Council
Final action: 3/21/2012
Title: Appeal of Patricia Noren to an Egress Window Non-Compliance Determination at 4 MAYWOOD PLACE.
Sponsors: Amy Brendmoen
Indexes: Ward - 5, Windows
Code sections:
Attachments: 1. 4 Maywood.appeal.2-8-12, 2. 4 Maywood Pl.Noren Ltr 2-24-12.pdf

Date	Ver.	Action By	Action	Result
3/27/2012	2	Mayor's Office	Signed	
3/21/2012	2	City Council	Adopted	Pass
2/21/2012	1	Legislative Hearings	Referred	

Appeal of Patricia Noren to an Egress Window Non-Compliance Determination at 4 MAYWOOD PLACE.

I would please address the committee to approve my installed windows. We just replaced the same style and size that was originally installed.

February 8, 2012

Virgil Tomas

No hearing necessary.

Yes, 7 inches egress opening height and 3 inches egress opening height

WHEREAS, in the matter of the Appeal of Patricia Noren to an Egress Window Non-Compliance Determination at 4 MAYWOOD PLACE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 7-inch variance on the openable height of double hung replacement egress bedroom window(s) measuring 17 inches high by 36 inches wide, and grant a 3-inch variance on the openable height of double hung replacement egress bedroom window(s) measuring 21 inches high by 37 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.