



Legislation Details (With Text)

File #: RLH WP 12- 24 **Version:** 1
Type: Resolution LH Window Permit **Status:** Passed
In control: City Council
Final action: 3/21/2012
Title: Appeal of Angen Xiong to an Egress Window Non-Compliance Determination at 1086 GALTIER STREET.
Sponsors: Amy Brendmoen
Indexes: Ward - 5, Windows
Code sections:
Attachments: 1. 1086 Galtier.appeal.2-9-12, 2. 1086 Galtier St.Xiong Ltr 2-24-12.pdf

Date	Ver.	Action By	Action	Result
3/27/2012	1	Mayor's Office	Signed	
3/21/2012	1	City Council	Adopted	Pass
2/21/2012	1	Legislative Hearings	Referred	

Appeal of Angen Xiong to an Egress Window Non-Compliance Determination at 1086 GALTIER STREET.

Window x 1

February 9, 2012

J. Hoffman

No hearing necessary.

Appeal was not entered into system until 2/23/12. Appeal got missed. -mxv

Grant 6-inch egress opening.

WHEREAS, in the matter of the Appeal of Angen Xiong to an Egress Window Non-Compliance Determination at 1086 GALTIER STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council Grant a 6-inch variance on the openable height of one double hung replacement bedroom egress window measuring 18 inches high by 21 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.