



## Legislation Details (With Text)

**File #:** RLH FOW      **Version:** 2  
12-52

**Type:** Resolution LH Fire Ordered Windows      **Status:** Passed

**In control:** City Council

**Final action:** 3/21/2012

**Title:** Appeal of Jesse Jacobsen to a Fire Certificate of Occupancy Correction Notice at 1596 WILSON AVENUE.

**Sponsors:** Kathy Lantry

**Indexes:** Fire C of O Letter, Ward - 7, Windows

**Code sections:**

**Attachments:** 1. 1596 Wilson.appeal.2-1-12.pdf, 2. 1596 Wilson Ave.Jacobsen Ltr 2-20-12.pdf

Date	Ver.	Action By	Action	Result
3/27/2012	2	Mayor's Office	Signed	
3/21/2012	2	City Council	Adopted	Pass
2/14/2012	1	Legislative Hearings	Referred	

Appeal of Jesse Jacobsen to a Fire Certificate of Occupancy Correction Notice at 1596 WILSON AVENUE.

The existing windows are original to the house and are in good working condition. Asking for a variance on the main level and upstairs windows only. We will be replacing the hardware on the lower level casement window to meet egress code.

January 24, 2012

Wayne Spiering

Hearing necessary on basement bedroom.

Yes: main floor - 4 inches egress opening height; upper floor - 8 inches egress opening height.

WHEREAS, in the matter of the Appeal of Jesse Jacobsen to a Fire Certificate of Occupancy Correction Notice at 1596 WILSON AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the openable height of the egress windows in the main floor southwest and southeast bedrooms; grant an 8-inch variance on the openable height of the egress windows in the upper floor southeast, southwest, and northwest bedrooms; and deny the appeal on the basement bedroom egress window; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.