



Legislation Details (With Text)

File #: RLH FCO 12- 122 **Version:** 2

Type: Resolution LH Fire C of O OR Correction Order **Status:** Passed

In control: City Council

Final action: 4/4/2012

Title: Appeal of Amy Westerlund to a Fire Certificate of Occupancy Inspection Correction Notice at 1245 FIFTH STREET EAST.

Sponsors: Kathy Lantry

Indexes: Fire C of O Letter, Ward - 7, Windows

Code sections:

Attachments: 1. 1245 5th.appeal.2-16-12.pdf, 2. 1245 Fifth St E.Westerlund Ltr.3-8-12.pdf, 3. 1245 5th St.Receipts & Docs.3-5-12.pdf, 4. 1252 Wilson.Dr Barsanti Letter.2-27-12.pdf, 5. 1252 Wilson.Exhibit A.3-6-12

Date	Ver.	Action By	Action	Result
4/10/2012	2	Mayor's Office	Signed	
4/4/2012	2	City Council	Adopted	Pass
3/6/2012	1	Legislative Hearings	Referred	

Appeal of Amy Westerlund to a Fire Certificate of Occupancy Inspection Correction Notice at 1245 FIFTH STREET EAST.

Item #1 - dryer vent
Item #2 - Egress windows
Item #4 - Chimney

February 14, 2012

Wayne Spiering

2/22/12-Appellant called and wanted to add Item 1 (dryer vent) to her appeal and also to reschedule her hearing. mxv

Hearing on the balance of the appeal.

Yes, 4 inches egress opening height.

WHEREAS, in the matter of the Appeal of Amy Westerlund to a Fire Certificate of Occupancy Inspection Correction Notice at 1245 FIFTH STREET EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council 1) grant a 4-inch variance on the openable height of the egress window in the main floor northeast bedroom; 2) grant a 3-inch variance on the openable height of the upper floor bedroom; 3) deny the appeal on the dryer vent and ground outlet issues and grant an extension for 90 days to come into compliance; and 4) grant that the appellant can be removed from the Fire C of O program after compliance with orders; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.