



## Legislation Details (With Text)

**File #:** RLH FOW 12-88 **Version:** 2  
**Type:** Resolution LH Fire Ordered Windows **Status:** Passed  
**In control:** City Council  
**Final action:** 4/4/2012  
**Title:** Appeal of Tony Swanson, Saint Paul Public Housing Agency, to a Fire Certificate of Occupancy Inspection Correction Notice at 876 SHERWOOD AVENUE.  
**Sponsors:** Dan Bostrom  
**Indexes:** Fire C of O Letter, Ward - 6, Windows  
**Code sections:**  
**Attachments:** 1. 876 Sherwood.appeal.2-24-12.pdf, 2. Egress Windows - PHA letter, 3-6-12 Hrg - 3-9-12.pdf

Date	Ver.	Action By	Action	Result
4/10/2012	2	Mayor's Office	Signed	
4/4/2012	2	City Council	Adopted	Pass
3/6/2012	1	Legislative Hearings	Referred	

Appeal of Tony Swanson, Saint Paul Public Housing Agency, to a Fire Certificate of Occupancy Inspection Correction Notice at 876 SHERWOOD AVENUE.

#1 - Request variance on openable height.

February 6, 2012

Mike Cassidy

No hearing necessary.

Yes, 5 inches egress opening height.

WHEREAS, in the matter of the Appeal of Tony Swanson, Saint Paul Public Housing Agency, to a Fire Certificate of Occupancy Inspection Correction Notice at 876 SHERWOOD AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4.5-inch variance on the openable height of the egress window in the second floor bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.