



Legislation Details (With Text)

File #: RLH FOW 12-85 **Version:** 2

Type: Resolution LH Fire Ordered Windows **Status:** Passed

In control: City Council

Final action: 4/4/2012

Title: Appeal of Tony Swanson, Saint Paul Public Housing Agency, to a Fire Certificate of Occupancy Inspection Correction Notice at 1222 DESOTO STREET.

Sponsors: Amy Brendmoen

Indexes: Fire C of O Letter, Ward - 5, Windows

Code sections:

Attachments: 1. 1222 Desoto.appeal.2-24-12.pdf, 2. Egress Windows - PHA letter, 3-6-12 Hrg - 3-9-12.pdf, 3. Egress Windows - PHA Revsied letter, 3-6-12 Hrg - 3-9-12.pdf

| Date | Ver. | Action By | Action | Result |
|-----------|------|----------------------|----------|--------|
| 4/10/2012 | 2 | Mayor's Office | Signed | |
| 4/4/2012 | 2 | City Council | Adopted | Pass |
| 3/6/2012 | 1 | Legislative Hearings | Referred | |

Appeal of Tony Swanson, Saint Paul Public Housing Agency, to a Fire Certificate of Occupancy Inspection Correction Notice at 1222 DESOTO STREET.

#3 Southeast and northeast bedroom - Request variance on openable width.

#4 Southwest bedroom - Request variance on openable height.

February 6, 2012

Mike Cassidy

No hearing necessary.

Yes, southeast and northeast bedrooms - 1 inch egress opening width and southwest bedroom - 5 inches egress opening height.

WHEREAS, in the matter of the Appeal of Tony Swanson, Saint Paul Public Housing Agency, to a Fire Certificate of Occupancy Inspection Correction Notice at 1222 DESOTO STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 1-inch variance on the openable width of the egress windows in the southeast and northeast bedrooms, and grant a 5-inch variance on the openable height of the egress window in the southwest bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.