

City of Saint Paul

City Hall and Court House 15 West Kellogg Boulevard Phone: 651-266-8560

Legislation Details (With Text)

File #: RLH FOW Version: 2

12-79

Type: Resolution LH Fire Ordered

Windows

Status: Passed

In control: City Council

Final action: 4/18/2012

Title: Appeal of Pete Lehner to a Fire Certificate of Occupancy Inspection Correction Notice at 2040

ASHLAND AVENUE.

Sponsors: Russ Stark

Indexes: Fire C of O Letter, Ward - 4, Windows

Code sections:

Attachments: 1. 2040 Ashland.appeal.2-17-12.pdf, 2. 2040 Ashland.photos.pdf, 3. 2040 Ashland Ave.Lehner Ltr 3-2-

12.pdf, 4. 2040 Ashland Ave.Lehner Ltr 3-28-12.pdf

Date	Ver.	Action By	Action	Result
4/25/2012	2	Mayor's Office	Signed	
4/18/2012	2	City Council	Adopted	
3/27/2012	1	Legislative Hearings	Referred	
2/28/2012	1	Legislative Hearings	Laid Over	

Appeal of Pete Lehner to a Fire Certificate of Occupancy Inspection Correction Notice at 2040 ASHLAND AVENUE.

(Appealing Item 1 which mentions two windows. See letter for details.)

February 9, 2012

Mitchell Imbertson

Hearing necessary for rear bedroom with egress opening width of 15 inches.

Yes, front bedroom - 5 inches egress opening height and a 3-inch variance on the openable width of the egress window in the first floor rear bedroom.

WHEREAS, in the matter of the Appeal of Pete Lehner to a Fire Certificate of Occupancy Inspection Correction Notice at 2040 ASHLAND AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of the egress window in the first floor front bedroom, and grant a 3-inch variance on the openable width of the egress window in the first floor rear bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.

File #: RLH FOW 12-79, Version: 2