



Legislation Details (With Text)

File #: RLH FOW 12-132 **Version:** 2

Type: Resolution LH Fire Ordered Windows **Status:** Passed

In control: City Council

Final action: 5/16/2012

Title: Appeal of Joseph Kummer to a Fire Inspection Correction Notice at 1025 MARGARET STREET.

Sponsors: Kathy Lantry

Indexes: Fire C of O Letter, Ward - 7, Windows

Code sections:

Attachments: 1. 1025 Margaret.appeal.4-10-12, 2. 1025 Margaret St.Kummer 4-19-12.pdf

Date	Ver.	Action By	Action	Result
5/18/2012	2	Mayor's Office	Signed	
5/16/2012	2	City Council	Adopted	Pass
4/17/2012	1	Legislative Hearings	Referred	

Appeal of Joseph Kummer to a Fire Inspection Correction Notice at 1025 MARGARET STREET.

Window is compliant width and 2" short on height

April 2, 2012

James Thomas

No hearing necessary.

Yes, 2 inches egress opening height. Note, orders not necessary on windows of these dimensions.

WHEREAS, in the matter of the Appeal of Joseph Kummer to a Fire Inspection Correction Notice at 1025 MARGARET STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of the egress windows in all bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.