



Legislation Details (With Text)

File #: RLH FCO 12- **Version:** 2
179

Type: Resolution LH Fire C of O OR **Status:** Passed
Correction Order

In control: City Council

Final action: 5/2/2012

Title: Appeal of Angela Goss, on behalf of CMP3, LLC, to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 957 THIRD STREET EAST.

Sponsors: Kathy Lantry

Indexes: Fire C of O Letter, Ward - 7

Code sections:

Attachments: 1. 957 Third E.appeal.3-13-12.pdf, 2. 957 Third St E.Goss Ltr 3-22-12.pdf, 3. 957 Third St E.Goss Ltr 4-5-12.pdf

Date	Ver.	Action By	Action	Result
5/7/2012	2	Mayor's Office	Signed	
5/2/2012	2	City Council	Adopted As Amended	Pass
4/3/2012	1	Legislative Hearings	Referred	
3/20/2012	1	Legislative Hearings	Laid Over	

Appeal of Angela Goss, on behalf of CMP3, LLC, to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 957 THIRD STREET EAST.

1. Basement water heaters for both units have been in basement since we purchased and renovated home in 2008. See attached C of O from Steve Zaccard Fire Marshall dated November 24, 2008. These have not been an issue and request that we can leave them both where they are installed. We could lock both residents out of basement if you prefer?
2. Egress Windows in lower unit (double hung) south bedroom is 14.5 w by 29.5 h-openable and 13.5 w X 65 h-glazed. Request variance from openable width by 5.5 inches but we are 5.5 inches higher than required height. Please note we have two windows that are identical. Code requires 44 sq. inches and our window is 44 sq. inches. We believe we meet the glazed area requirement.

March 12, 2012

Wayne Spiering

AMENDED 5/2/12

WHEREAS, in the matter of the Appeal of Angela Goss, on behalf of CMP3, LLC, to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 957 THIRD STREET EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council deny the appeal on the lower unit south bedroom egress window and grant a 90-day extension for compliance, and deny the appeal on the water heaters and grant an extension to September 1, 2012 for compliance; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby ~~accepts and adopts the Legislative Hearing Officer's recommendation~~ grants the appeal in this matter.