



## Legislation Details (With Text)

**File #:** RLH FOW 12-117 **Version:** 2

**Type:** Resolution LH Fire Ordered Windows **Status:** Passed

**In control:** City Council

**Final action:** 5/2/2012

**Title:** Appeal of Gajpov N. Yang to an Egress Window Non-Compliance Determination at 1233 BRADLEY STREET.

**Sponsors:** Amy Brendmoen

**Indexes:** Fire C of O Letter, Ward - 5, Windows

**Code sections:**

**Attachments:** 1. 1233 Bradley.appeal.3-28-12, 2. 1233 Bradley St.Yang Ltr 4-13-12.pdf

Date	Ver.	Action By	Action	Result
5/7/2012	2	Mayor's Office	Signed	
5/2/2012	2	City Council	Adopted	Pass
4/10/2012	1	Legislative Hearings	Referred	

Appeal of Gajpov N. Yang to an Egress Window Non-Compliance Determination at 1233 BRADLEY STREET.

I would like to appeal and request a variance for #2 on the deficiency list. The window is the original window that came with the house and has previously been acceptable for past C of O. With the exception of the size, the window is still in operable condition.

March 14, 2012

Mike Cassidy

No hearing necessary.

Yes, 2 inches egress opening height. Orders were unnecessary for windows of these dimensions.

WHEREAS, in the matter of the Appeal of Gajpov N. Yang to a Fire Inspection Correction Notice at 1233 Bradley Street, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant 2 inches variance in the egress window opening height; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.