



Legislation Details (With Text)

File #: RLH WP 12- 31 **Version:** 2
Type: Resolution LH Window Permit **Status:** Passed
In control: City Council
Final action: 5/2/2012
Title: Appeal of Minnesota Rusco, on behalf of Joko Sutrisno and Tri Martodikromo, to three Egress Window Non-Compliance Determinations at 883 PARKVIEW AVENUE.
Sponsors: Amy Brendmoen
Indexes: Ward - 5, Windows
Code sections:
Attachments: 1. 883 Parkview.appeal.3-21-12.pdf, 2. 883 Parkview Ave.MN Rusco Revised Ltr 4-13-12.pdf

Date	Ver.	Action By	Action	Result
5/7/2012	2	Mayor's Office	Signed	
5/2/2012	2	City Council	Adopted	Pass
4/10/2012	1	Legislative Hearings	Referred	

Appeal of Minnesota Rusco, on behalf of Joko Sutrisno and Tri Martodikromo, to three Egress Window Non-Compliance Determinations at 883 PARKVIEW AVENUE.

(See attached letter from Minnesota Rusco.)

April 3, 2012

J. Hoffman

Staff just received on 4-3-12 the proper paperwork for this appeal.
No hearing necessary.

Yes:
For window with egress opening of 17"H x 24"W - 7 inch variance in egress opening height and no variance needed for glazed area (it's calculated incorrectly)
For window with egress opening of 20"H x 24"W - 4 inch variance in egress opening height and no variance needed for glazed area (it's calculated incorrectly)
For window with egress opening of 20"H x 19"W - 4 inch variance in egress opening height, 1 inch egress opening width and no variance needed for glazed area (it's calculated incorrectly)

WHEREAS, in the matter of the Appeal of Minnesota Rusco, on behalf of Joko Sutrisno and Tri Martodikromo, to three Egress Window Non-Compliance Determinations at 883 PARKVIEW AVENUE; the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant the following variances:
1) for window with egress opening of 17"H x 24"W - 7 inch variance in egress opening height and no variance needed for glazed area; 2) for window with egress opening of 20"H x 24"W - 4 inch variance in egress opening height and no variance needed for glazed area; and 3) for window with egress opening of 20"H x 19"W - 4

inch variance in egress opening height, 1 inch egress opening width and no variance needed for glazed area;
Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.