



## Legislation Details (With Text)

**File #:** RLH FOW 12-118 **Version:** 2

**Type:** Resolution LH Fire Ordered Windows **Status:** Passed

**In control:** City Council

**Final action:** 5/2/2012

**Title:** Appeal of Randy McLevish to an Egress Window Non-Compliance Determination at 534 MARSHALL AVENUE.

**Sponsors:** Melvin Carter III

**Indexes:** Fire C of O Letter, Ward - 1, Windows

**Code sections:**

**Attachments:** 1. 534 Marshall.appeal.3-28-12, 2. 534 Marshall Ave.McLevish Ltr 4-13-12.pdf

Date	Ver.	Action By	Action	Result
5/7/2012	2	Mayor's Office	Signed	
5/2/2012	2	City Council	Adopted	Pass
4/10/2012	1	Legislative Hearings	Referred	

Appeal of Randy McLevish to an Egress Window Non-Compliance Determination at 534 MARSHALL AVENUE.

Opening size changed by Fire Marshall and very close double hung to new requirement size.

March 22, 2012

Rick Gavin

No hearing necessary.

Yes, 3 inches egress opening height. Orders unnecessary for windows of these dimensions.

WHEREAS, in the matter of the Appeal of Randy McLevish to an Egress Window Non-Compliance Determination at 534 MARSHALL AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 3-inch variance in the egress opening of the listed windows; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.