



## Legislation Details (With Text)

**File #:** RLH FOW      **Version:** 2  
12-135

**Type:** Resolution LH Fire Ordered      **Status:** Passed  
Windows

**In control:** City Council

**Final action:** 5/16/2012

**Title:** Appeal of Tony Swanson, Public Housing Agency, to a Fire Certificate of Occupancy Correction Notice at 757 IGLEHART AVENUE.

**Sponsors:** Melvin Carter III

**Indexes:** Fire C of O Letter, Ward - 1, Windows

**Code sections:**

**Attachments:** ,

Date	Ver.	Action By	Action	Result
5/18/2012	2	Mayor's Office	Signed	
5/16/2012	2	City Council	Adopted	Pass
4/17/2012	1	Legislative Hearings	Referred	

Appeal of Tony Swanson, Public Housing Agency, to a Fire Certificate of Occupancy Correction Notice at 757 IGLEHART AVENUE.

egress windows

March 13, 2012

Rick Gavin

No hearing necessary.

Yes - 4-inch variance width in egress opening.

WHEREAS, in the matter of Tony Swanson, Public Housing Agency, to a Fire Certificate of Occupancy Correction Notice at 757 IGLEHART AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the openable width of the egress windows in all bedrooms measuring 45 inches high by 16 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.