



Legislation Details (With Text)

File #: RLH FOW 12-144 **Version:** 2

Type: Resolution LH Fire Ordered Windows **Status:** Passed

In control: City Council

Final action: 5/16/2012

Title: Appeal of Ernest Strecker to a Fire Inspection Correction Notice at 1884 NEVADA AVENUE EAST.

Sponsors: Dan Bostrom

Indexes: Fire C of O Letter, Ward - 6, Windows

Code sections:

Attachments: 1. 1884 Nevada.appeal.4-18-12, 2. 1884 Nevada Ave E.Strecker Ltr 4-26-12.pdf

Date	Ver.	Action By	Action	Result
5/18/2012	2	Mayor's Office	Signed	
5/16/2012	2	City Council	Adopted	Pass
4/24/2012	1	Legislative Hearings	Referred	

Appeal of Ernest Strecker to a Fire Inspection Correction Notice at 1884 NEVADA AVENUE EAST.

Appealing windows

April 13, 2012

James Thomas

No hearing necessary.

Yes, 4 inches egress opening height. THIS ORDER WAS NOT NECESSARY GIVEN THE DIMENSIONS OF THE OVERALL EGRESS OPENING.

WHEREAS, in the matter of the Appeal of Ernest Strecker to a Fire Inspection Correction Notice at 1884 NEVADA AVENUE EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the openable height of the egress windows in all bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.