



## Legislation Details (With Text)

**File #:** RLH FOW 12-150 **Version:** 2

**Type:** Resolution LH Fire Ordered Windows **Status:** Passed

**In control:** City Council

**Final action:** 6/6/2012

**Title:** Appeal of Charles Maguire to a Fire Inspection Correction Notice at 1808 PORTLAND AVENUE.

**Sponsors:** Russ Stark

**Indexes:** Fire C of O Letter, Ward - 4, Windows

**Code sections:**

**Attachments:** 1. 1808 Portland.appeal.5-8-12.pdf, 2. 1808 Portland Ave.Maguire Ltr 5-10-12.pdf

Date	Ver.	Action By	Action	Result
6/11/2012	2	Mayor's Office	Signed	
6/6/2012	2	City Council	Adopted	Pass
5/8/2012	1	Legislative Hearings	Referred	

Appeal of Charles Maguire to a Fire Inspection Correction Notice at 1808 PORTLAND AVENUE.

Windows on 2nd & 3rd floor; windows needing to be open 24"; not realistic for all windows.

March 27, 2012

Mitchell Imbertson

No hearing necessary.

Yes, east unit 3rd floor - 2 inches egress opening height; west unit 2nd floor southwest bedroom - 2 inches egress opening height; 2nd floor southwest porch room - 4 inches egress opening height; 3rd floor - 4 inches egress opening height. ORDERS WERE NOT NECESSARY FOR WINDOWS ON THESE DIMENSIONS.

WHEREAS, in the matter of the Appeal of Charles Maguire to a Fire Certificate of Occupancy Inspection Correction Notice at 1808 PORTLAND AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of the egress window in the East Unit third floor south bedroom; grant a 2-inch variance on the openable height of the egress window in the second floor southwest bedroom; grant a 4-inch variance on the openable height of the egress window in the second floor southwest porch room; and grant a 4-inch variance on the openable height of the egress window in the third floor bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.