



Legislation Details (With Text)

File #: RLH WP 12- 42 **Version:** 2
Type: Resolution LH Window Permit **Status:** Passed
In control: City Council
Final action: 6/6/2012
Title: Appeal of Ramsey County Public Health, to an Egress Window Non-Compliance Determination at 1298 SEMINARY AVENUE.
Sponsors: Russ Stark
Indexes: Ward - 4, Windows
Code sections:
Attachments: 1. 1298 Seminary.appeal.4-24-12, 2. 1298 Seminary Ave.Public Health Ltr 5-8-12.pdf

Date	Ver.	Action By	Action	Result
6/11/2012	2	Mayor's Office	Signed	
6/6/2012	2	City Council	Adopted	Pass
5/1/2012	1	Legislative Hearings	Referred	

Appeal of Ramsey County Public Health, to an Egress Window Non-Compliance Determination at 1298 SEMINARY AVENUE.

Windows

April 24, 2012

No hearing necessary.

Yes, 4.5 inches egress opening height.

WHEREAS, in the matter of the Appeal of Daniel Schmidt, on behalf of Ramsey County Public Health, to an Egress Window Non-Compliance Determination at 1298 SEMINARY AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4.5-inch variance on the openable height of three double hung replacement egress bedroom windows measuring 19.9 inches high by 25.2 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.