



## Legislation Details (With Text)

<b>File #:</b>	RLH FOW 12-139	<b>Version:</b>	2
<b>Type:</b>	Resolution LH Fire Ordered Windows	<b>Status:</b>	Passed
		<b>In control:</b>	City Council
		<b>Final action:</b>	6/6/2012
<b>Title:</b>	Appeal of Kirk Anderson to a Fire Inspection Correction Notice at 1419 ALASKA AVENUE.		
<b>Sponsors:</b>	Chris Tolbert		
<b>Indexes:</b>	Fire C of O Letter, Ward - 3, Windows		
<b>Code sections:</b>			
<b>Attachments:</b>	1. 1419 Alaska.appeal.4-16-12, 2. 1419 Alaska Ave.Email.4-28-12.pdf, 3. 1419 Alaska.Vent Sketch.pdf, 4. 1419 Alaska Ave.Photo 1.pdf, 5. 1419 Alaska Ave.Photo 2.pdf, 6. 1419 Alaska Ave.Photo 3.pdf, 7. 1419 Alaska Ave.Anderson Ltr 4-26-12.pdf, 8. 1419 Alaska Ave.Anderson Ltr 5-10-12.pdf		

Date	Ver.	Action By	Action	Result
6/11/2012	2	Mayor's Office	Signed	
6/6/2012	2	City Council	Adopted	Pass
5/8/2012	1	Legislative Hearings	Referred	
4/24/2012	1	Legislative Hearings	Laid Over	

Appeal of Kirk Anderson to a Fire Inspection Correction Notice at 1419 ALASKA AVENUE.

See Attached

April 6, 2012

Rick Gavin

Hearing necessary as appellant does not want to install step, as indicated in the appeal.

Yes, 6 inches minimum sill height if 1 standard sized step is permanently attached for the full length of the window.

WHEREAS, in the matter of the Appeal of Kirk Anderson to a Fire Inspection Correction Notice at 1419 ALASKA AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant the appeal on the sill height provided the owner installs one step to the non-vented side below each egress window, and also install handholds; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.

