

Pass

Legislation Details (With Text)

| File #: | RLH WP 12- Version: 2 | | | |
|----------------|----------------------------------------------------------------------------------------------------------------------------------------------------|---------------|--------------|--|
| _ | 40 | | | |
| Туре: | Resolution LH Window Permit | Status: | Passed | |
| | | In control: | City Council | |
| | | Final action: | 6/6/2012 | |
| Title: | Appeal of Daniel Schmidt, on behalf of Ramsey County Public Health, to an Egress Window Non- Compliance Determination at 1131 JESSIE STREET #1. | | | |
| Sponsors: | Amy Brendmoen | | | |
| Indexes: | Ward - 5, Windows | | | |
| Code sections: | | | | |
| Attachments: | 1. 1131 Jessie.appeal.4-24-12, 2. 1131 Jessie St.Public Health Ltr 5-8-12.pdf | | | |
| Date | Ver. Action By | Acti | ion Result | |
| 6/11/2012 | 2 Mayor's Office | Sigi | ned | |

| 6/6/2012 | 2 | City Council | Adopted |
|----------|---|----------------------|----------|
| 5/1/2012 | 1 | Legislative Hearings | Referred |

Appeal of Daniel Schmidt, on behalf of Ramsey County Public Health, to an Egress Window Non-Compliance Determination at 1131 JESSIE STREET #1.

Windows

April 24, 2012

No hearing necessary.

Yes, 3 inches egress opening width.

WHEREAS, in the matter of the Appeal of Daniel Schmidt, on behalf of Ramsey County Public Health, to an Egress Window Non-Compliance Determination at 1131 JESSIE STREET #1, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 3-inch variance on the openable width of one double hung replacement egress bedroom window measuring 27.9 inches high by 17.2 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.