



Legislation Details (With Text)

File #: RLH WP 12- 44 **Version:** 2
Type: Resolution LH Window Permit **Status:** Passed
In control: City Council
Final action: 6/6/2012
Title: Appeal of The Window Store Home Improvements, on behalf of Brandon Imsdahl, to an Egress Window Non-Compliance Determination at 1386 SCHLETTI STREET.
Sponsors: Amy Brendmoen
Indexes: Ward - 5, Windows
Code sections:
Attachments: 1. 1386 Schletti.appeal.5-3-12.pdf, 2. 1386 Schletti St.Window Store Ltr 5-10-12.pdf

Date	Ver.	Action By	Action	Result
6/11/2012	2	Mayor's Office	Signed	
6/6/2012	2	City Council	Adopted	Pass
5/8/2012	1	Legislative Hearings	Referred	

Appeal of The Window Store Home Improvements, on behalf of Brandon Imsdahl, to an Egress Window Non-Compliance Determination at 1386 SCHLETTI STREET.

Brandon doesn't want casement windows because they do not go with the character of this old house.

April 25, 2012

J. Hoffman

No hearing necessary.

Yes, 5 inches egress opening height.

WHEREAS, in the matter of the Appeal of The Window Store Home Improvements, on behalf of Brandon Imsdahl, to an Egress Window Non-Compliance Determination at 1386 SCHLETTI STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of two double hung replacement egress bedroom windows measuring 19 inches high by 27 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.