



Legislation Details (With Text)

File #: RLH FOW 12-166 **Version:** 2

Type: Resolution LH Fire Ordered Windows **Status:** Passed

In control: City Council

Final action: 6/20/2012

Title: Appeal of Joseph Sondag to a Fire Certificate of Occupancy Inspection Correction Notice at 1781 BLAIR AVENUE.

Sponsors: Russ Stark

Indexes: Fire C of O Letter, Ward - 4, Windows

Code sections:

Attachments: 1. 1781 Blair.appeal.5-7-12.pdf, 2. 1781 Blair Ave.Sondag Ltr 5-21-12.pdf

Date	Ver.	Action By	Action	Result
6/26/2012	2	Mayor's Office	Signed	
6/20/2012	2	City Council	Adopted	Pass
5/15/2012	1	Legislative Hearings	Referred	

Appeal of Joseph Sondag to a Fire Certificate of Occupancy Inspection Correction Notice at 1781 BLAIR AVENUE.

Only egress windows

May 3, 2012

Sebastian Migdal

No hearing necessary.

Yes, 4 inches egress opening height. ORDERS WERE NOT NECESSARY ON WINDOWS OF THESE DIMENSIONS.

WHEREAS, in the matter of the Appeal of Joseph Sondag to a Fire Certificate of Occupancy Inspection Correction Notice at 1781 BLAIR AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the openable height of the egress window in the lower level bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.