



## Legislation Details (With Text)

**File #:** RLH WP 12- 51 **Version:** 2

**Type:** Resolution LH Window Permit **Status:** Passed  
**In control:** City Council  
**Final action:** 6/20/2012

**Title:** Appeal of The Home Depot At Home Services, on behalf of Famata King, to an Egress Window Non-Compliance Determination at 1922 CLEAR AVENUE.

**Sponsors:** Dan Bostrom

**Indexes:** Ward - 6, Windows

**Code sections:**

**Attachments:** 1. 1922 Clear.appeal.5-14-12.pdf, 2. 1922 Clear Ave.Home Depot Ltr 5-21-12.pdf

Date	Ver.	Action By	Action	Result
6/25/2012	2	Mayor's Office	Signed	
6/20/2012	2	City Council	Adopted	Pass
5/22/2012	1	Legislative Hearings	Referred	

Appeal of The Home Depot At Home Services, on behalf of Famata King, to an Egress Window Non-Compliance Determination at 1922 CLEAR AVENUE.

We replaced 1 double hung window (like for like) in a twin DH configuration. Homeowner wanted new window to match.

April 19, 2012

David Nelson

No hearing necessary.

Yes, 4 inches egress opening height.

WHEREAS, in the matter of the Appeal of The Home Depot At Home Services, on behalf of Famata King, to an Egress Window Non-Compliance Determination at 1922 CLEAR AVENUE; the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the openable height of two double hung replacement egress bedroom windows measuring 20 inches high by 22 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.