



## Legislation Details (With Text)

**File #:** RLH FOW 12-185 **Version:** 2

**Type:** Resolution LH Fire Ordered Windows **Status:** Passed

**In control:** City Council

**Final action:** 6/20/2012

**Title:** Appeal of James Bobzien to an Updated Fire Inspection Correction Notice at 1637 VAN BUREN AVENUE.

**Sponsors:** Russ Stark

**Indexes:** Fire C of O Letter, Ward - 4, Windows

**Code sections:**

**Attachments:** 1. 1637 Van Buren.appeal.5-11-12, 2. 1637 Van Burne Ave.Bobzien Ltr 5-29-12.pdf

Date	Ver.	Action By	Action	Result
6/26/2012	2	Mayor's Office	Signed	
6/20/2012	2	City Council	Adopted	Pass
5/22/2012	1	Legislative Hearings	Referred	

Appeal of James Bobzien to an Updated Fire Inspection Correction Notice at 1637 VAN BUREN AVENUE.

See attachment - Page 1

May 4, 2012

Mitchell Imbertson

No hearing necessary.

Yes, 4 inches egress opening height.

WHEREAS, in the matter of the Appeal of James Bobzien to an Updated Fire Inspection Correction Notice at 1637 VAN BUREN AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 3.5-inch variance on the openable height of the egress window in the third floor bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.