City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

City of Saint Paul

Legislation Details (With Text)

File #:	RLH FOW 12-183 **Version:** 2		
Type:	Resolution LH Fire Ordered Windows	**Status:**	Passed
		In control:	City Council
		Final action:	7/3/2012
Title:	Appeal of Gerald Yost to a Fire Inspection Correction Notice at 422 MOUNT CURVE BOULEVARD.		
Sponsors:	Chris Tolbert		
Indexes:	Fire C of O Letter, Ward - 3, Windows		
Code sections:			
Attachments:	1. 422 Mt. Curve.appeal.5-11-12, 2. 422 Mt. Curve Blvd.Yost Ltr 6-11-12.pdf		

Date	Ver.	Action By	Action	Result
7/9/2012	2	Mayor's Office	Signed	
7/3/2012	2	City Council	Adopted	Pass
6/5/2012	1	Legislative Hearings	Referred	

Appeal of Gerald Yost to a Fire Inspection Correction Notice at 422 MOUNT CURVE BOULEVARD.

Windows

May 2, 2012

Jay Bohan

No hearing necessary.

Yes, 3 inches egress opening height.

WHEREAS, in the matter of the Appeal of Gerald Yost to a Fire Inspection Correction Notice at 422 MOUNT CURVE BOULEVARD, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 3-inch variance on the openable height of the egress windows in the east and west bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.

powered by Legistar™