



Legislation Details (With Text)

**File #:** RLH FOW      **Version:** 2  
12-183

**Type:** Resolution LH Fire Ordered      **Status:** Passed  
Windows

**In control:** City Council

**Final action:** 7/3/2012

**Title:** Appeal of Gerald Yost to a Fire Inspection Correction Notice at 422 MOUNT CURVE BOULEVARD.

**Sponsors:** Chris Tolbert

**Indexes:** Fire C of O Letter, Ward - 3, Windows

**Code sections:**

**Attachments:** 1. 422 Mt. Curve.appeal.5-11-12, 2. 422 Mt. Curve Blvd.Yost Ltr 6-11-12.pdf

Date	Ver.	Action By	Action	Result
7/9/2012	2	Mayor's Office	Signed	
7/3/2012	2	City Council	Adopted	Pass
6/5/2012	1	Legislative Hearings	Referred	

Appeal of Gerald Yost to a Fire Inspection Correction Notice at 422 MOUNT CURVE BOULEVARD.

Windows

May 2, 2012

Jay Bohan

No hearing necessary.

Yes, 3 inches egress opening height.

WHEREAS, in the matter of the Appeal of Gerald Yost to a Fire Inspection Correction Notice at 422 MOUNT CURVE BOULEVARD, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 3-inch variance on the openable height of the egress windows in the east and west bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.