



## Legislation Details (With Text)

**File #:** RLH WP 12- 53 **Version:** 2  
**Type:** Resolution LH Window Permit **Status:** Passed  
**In control:** City Council  
**Final action:** 7/3/2012  
**Title:** Appeal of Window World to an Egress Window Non-Compliance Determination at 1029 BUSH AVENUE.  
**Sponsors:** Dan Bostrom  
**Indexes:** Ward - 6, Windows  
**Code sections:**  
**Attachments:** 1. 1029 Bush.appeal.5-14-12.pdf, 2. 1029 Bush Ave.Window World Ltr 6-13-12.pdf

Date	Ver.	Action By	Action	Result
7/9/2012	2	Mayor's Office	Signed	
7/3/2012	2	City Council	Adopted	Pass
6/5/2012	1	Legislative Hearings	Referred	

Appeal of Window World to an Egress Window Non-Compliance Determination at 1029 BUSH AVENUE.

Only Egress Windows

May 8, 2012

Form completed by Molly McGrane from Window World

No hearing necessary.

Yes, 2 inches egress opening height. Variance based on window specs attached to appeal.

WHEREAS, in the matter of the Appeal of Window World to an Egress Window Non-Compliance Determination at 1029 BUSH AVENUE; the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of one slider replacement egress bedroom window measuring 22.81 inches high by 22.06 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.