



Legislation Details (With Text)

File #: RLH FOW **Version:** 2
12-209

Type: Resolution LH Fire Ordered Windows **Status:** Passed

In control: City Council

Final action: 7/3/2012

Title: Appeal of James and Judith Wiberg to a Fire Inspection Correction Notice at 2184 ELEANOR AVENUE.

Sponsors: Chris Tolbert

Indexes: Fire C of O Letter, Ward - 3, Windows

Code sections:

Attachments: 1. 2184 Eleanor.appeal.5-25-12, 2. 2184 Eleanor Ave.Wiberg Ltr 6-18-12.pdf

Date	Ver.	Action By	Action	Result
7/9/2012	2	Mayor's Office	Signed	
7/3/2012	2	City Council	Adopted	Pass
6/12/2012	1	Legislative Hearings	Referred	

Appeal of James and Judith Wiberg to a Fire Inspection Correction Notice at 2184 ELEANOR AVENUE.

Egress Window

May 2, 2012

Jay Bohan

No hearing necessary.

Yes, 5 inches egress opening height.

WHEREAS, in the matter of the Appeal of James and Judith Wiberg to a Fire Inspection Correction Notice at 2184 ELEANOR AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of the egress window in the second floor southeast bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.