



Legislation Details (With Text)

File #: RLH FOW 12-221 **Version:** 2

Type: Resolution LH Fire Ordered Windows **Status:** Passed

In control: City Council

Final action: 7/3/2012

Title: Appeal of Roxanne W. Larsen to a Fire Inspection Correction Notice at 684 ROSE AVENUE EAST.

Sponsors: Dan Bostrom

Indexes: Fire C of O Letter, Ward - 6, Windows

Code sections:

Attachments: 1. 684 Rose St.appeal.5-31-12, 2. 684 Rose Ave E.Larsen Ltr 6-18-12.pdf

| Date | Ver. | Action By | Action | Result |
|-----------|------|----------------------|----------|--------|
| 7/9/2012 | 2 | Mayor's Office | Signed | |
| 7/3/2012 | 2 | City Council | Adopted | Pass |
| 6/12/2012 | 1 | Legislative Hearings | Referred | |

Appeal of Roxanne W. Larsen to a Fire Inspection Correction Notice at 684 ROSE AVENUE EAST.

See attachment

May 2, 2012

Benjamin Ellis

No hearing necessary.

Yes, 3 inches egress opening height.

WHEREAS, in the matter of the Appeal of Roxanne W. Larsen to a Fire Inspection Correction Notice at 684 ROSE AVENUE EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 3-inch variance on the openable height of the egress windows in the first floor south and north bedroom and second floor south and north bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.